



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Co.

**Guideline
For
Design, Testing and Installation
Of LV Switchgear**

GL.GN.02

Effective Date : 01/02/2012

Procedure No: GL.GN.02

Issue : 2

Revision : 1

Page 1 of 51

Approved by:

**Design, Testing and Installation
Of LV Switchgear**

Prepared by:

V P Murali
for LV Switchgear Committee

Date: 22.01.2012

Reviewed by:

Adel Marzouqi
for LV Switchgear Committee

Date: 22.01.2012

Approved by:

Ali Al Menhali
Chairman, LV Switchgear Committee

Date: 22.01.2012



Effective Date:
01/02/2012

7 Manufacturer/Suppliers Responsibility

Manufacturers are advised to use same components (with respect to the make, type, frame size, and current rating) that were used for the type testing. The type test report shall mention clearly these components along with their corresponding rating

It is the manufacturer/Supplier's responsibility to inform their Client about any Special conditions that were mentioned by ADDC LV Switchgear Committee in their prequalification letter.

8 Guideline for carrying out type test

8.1 ADDC Approved Third Party Inspectors/Certifying Agents

The following is the list of ADDC approved third party inspectors/Certifying agents who shall carryout the test/certify the type test certificates. ADDC will accept the type test certificate issued and certified by one of these agencies. The manufacturers are advised to type test their product as per the Guidelines stated in the document and get certified by one of these agencies.

It is mandatory that the test lab shall be certified as per BSEN ISO/IEC 17025 or Equivalent. The manufacturer shall submit documents to verify this requirement, as a part of the prequalification procedure.

1. DEKRA Certification B.V.
2. ASTA
3. LOVAG members as per the list below
 - ACAE – Italy
 - ALPHA at VDE (VDE Testing & Certification Institute), Germany
 - Applus+LGAI - Spain
 - ASEFA - France
 - Intertek Semko AB - Sweden
 - SGS Belgium, NV Division, SGS CEBEC – Belgium